



## Copper Cylinders - Grades & Anodes

### •Grade 3 Cylinders:-

Suitable for Reservoir supply only - 7.5 metre head - 20 psi.  
For use with open expansion systems only.

### •Grade 2 Cylinders:-

Suitable for well supply or “group scheme” - 11 metre head - 40 psi.  
For use with open expansion systems only.

### •Grade 1 Cylinders:-

Suitable for well supply or “group scheme” - 15 metre head - 60 psi.  
For use with open expansion systems only.

### •Anodes:-

A sacrificial anode is put in a cylinder to prolong the life of the cylinder in areas with aggressive water.